

## **PUBLIC NOTICE**

**MILLTOWN-WASHBURN WATER** is a public water system subject to regulations under the federal Safe Drinking Water Act. Those regulations require the notification of customers whenever a violation occurs, and is the basis for this notice.

The annual average of quarterly samples of the level of total trihalomethanes, a disinfection by-product, in the water exceeded the maximum contaminant level of 80 parts per billion for the period from July 2019 through September 2019. The average level in your water for site #773YD008 this period was 85 ppb.

The U.S. Environmental Protection Agency set national standards for drinking water and has established the maximum level for Total Trihalomethanes at 80 micrograms per liter. Trihalomethanes are a group of by-product chemicals which are formed by the use of chlorine in the treatment of drinking water. Disinfectants, such as chlorine, react with naturally occurring organic and inorganic matter present in water to form chemicals called disinfection byproducts (DBPs). EPA has determined that a number of DBPs are a health concern at certain levels of exposure.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. EPA has set standards to limit exposure to trihalomethanes, haloacetic acids, and other DBPs.

The Arkansas Department of Health has advised the water system that there is no immediate health risk from consuming the water. Failure to meet this requirement does not mean that the water is unsafe or that alternate sources of water should be used.

The water system is closely monitoring booster chlorination and has increased flushing of the system.

Should you have any questions concerning this notice, contact the water system at 479-996-7471 or the Engineering Section of the Department of Health at 501-661-2623.

Information on drinking water can be obtained from the Engineering Section at 501-661-2623 and on the health effects of Trihalomethanes from the Epidemiology Section at 501-661-2796.